


**Model #
CPVS**

**Chilled Water
Packaged Pumping System
Constant Primary / Variable Secondary**



U Unfired Pressure Vessels
9P Pressure Piping

TYPICAL SPECIFICATIONS	
System Return Temperature	38 to 68 deg F
Chilled Water Temperature	28 to 60 deg F
Standard System Flow Rate	5 to 3000 GPM
Standard Power	460 V (Other Voltages Available)
Dimensions	Based Upon Customer Requirements
Working Pressure	100 to 150 psig (6.8 to 10.2 barg)
Working Temperature	< 240 deg F (< 115 deg C)

EnviroSep CPVS, Constant Primary / Variable Secondary, Chilled Water Packaged Pumping System is a UL-Listed, factory manufactured system utilized in conventional building cooling systems which uses Chilled Water as the cooling medium. The **Model CPVS** provides significant **power savings** by automatically controlling the speed of the Secondary Pumps based on the actual building system demand. Differential Pressure Transmitters (or alternate sensors) signal the Non-proprietary PLC-based, Variable Speed Controller to operate the pumps at the appropriate conditions to meet demand. Chilled Water Return is supplied to the System Chiller(s) and the Chilled Water Supply is decoupled through a common header. The **Model HTS-CPVS** may be controlled by other system variables, such as Total System Load (BTU/hr), System Pressure, or System Temperature via a customized Controller. **Variable Frequency Drives** may be incorporated with Manual or Automatic Bypasses. A User-friendly, Color Touch Screen Operator Interface is utilized for simple operation. The **Model HTS-CPVS** Controller may be furnished with Interface to any Building Management System. This fully integrated turn-key system speeds installation and start-up which provides significant, initial-investment savings to contractors, engineers, and building owners.

Standard Features:

- Base-mounted, End-suction Pumps or Split-coupled Vertical Inline Pumps
- Variable Frequency Drives & Controller
- Differential Pressure Transmitters
- Vortex Air Separator, with Auto Air Vent
- Bladder Expansion/Compression Tank
- Triple Duty Valves & Suction Diffusers
- UL Listed NEMA 12 Industrial Variable Speed System Control Panel, with Siemens S7-300 or Allen Bradley ConttoLogix PLC
- Make-up Water Assembly, with Safety Relief Valve
- Chemical Bypass Feeder
- System Temperature Transmitters
- Chilled Water Supply Flow Meter



Model CPVS Savings vs. Constant Speed

Pump Speed (%)	Potential Annual Savings	Pump Speed (%)	Potential Annual Savings
100	\$0	60	\$15,006
90	\$5,195	50	\$16,738
80	\$9,427	40	\$18,084
70	\$12,697	30	\$18,661

1. Savings are based on max. potential savings at max. pump capacity on 8600 hr/yr of continuous operation
2. Power Cost at \$ 0.12/kwh
3. Savings assume operation of One (1) 25 Hp Pump

Options:

- Internet Connectivity for Remote System Monitoring
- Interface w/ Building Management System
- Chiller Staging Capability
- NEMA 3R/4/4X Rating
- Seismic or Vibration Isolators
- Combination Air & Dirt Separator
- Flexible Pump Connectors
- Specific Performance Criteria (Upon Request)

P. O. Box 857 Georgetown, SC 29442 • Phone: 843-546-7400 Fax: 843-546-7407

Sep
Enviro



Specify the following parameters:

- I. System Cooling Load = _____ BTU/hr
- II. System Differential Pressure Required = _____ psid
- III. System Flow Rate = _____ GPM
- IV. System Inlet Pressure = _____ psig
- V. Return Temperature = 54 °F
- VI. Supply Temperature = 44 °F
- VII. System Electrical = _____ V _____ Hz
- VIII. System Volume = _____ Gal.

Note: System medium assumed to be water, unless otherwise specified.

SYSTEM OPTIONS

- Stand-by Pump
- System Pressure Gauges
- Pump Suction Diffuser
- Vertical In-line Pump
- Split-coupled Vertical In-line Pump
- Closed-coupled end-suction Centrifugal Pump
- Auto standby pump start on lead pump failure
- Auto Pump Alternation
- Remote start connection
- Variable Frequency Drives
 - Manual Bypass
 - Automatic Bypass
- Remote System Monitoring
 - Ethernet
 - Dial-up Modem
- Communication Protocol
 - Ethernet I/P
 - Modbus RTU
 - Siemens FLN
 - Johnson Controls N2
 - BACnet (MS/TP)
 - Lon Works
 - Profibus
 - DeviceNet
- System drain valves
- Flexible Connectors
- Vibration Isolation
- Control Valve Bypass and Isolation
- Panel-mounted Differential Pressure Gauges
- Pump Run-time Hour Meter
- Outdoor-use Rating
- Outdoor Cabinet
- System Inlet/Outlet Isolation Valves
- System Flow Switch
- Differential Pressure Switch across Pump suction/ discharge

Regardless of system size, temperature, pressure, fluid medium, or space requirements, *EnviroSep* can provide solutions to all specialized needs.

Model #
CPVS

Typical Specifications for CPVS

Furnish and install one *EnviroSep* Model CPVS- [A] - [B] - [C] - [D] Chilled Water Packaged Pumping System with the system capacity to cool _____ BTU/hr of _____ (fluid) from _____ psig to _____ psig.

KEY:

[A] = Model # (BTU/hr)
[B] = # of pumps (1,2,3,etc.)
[C] = Parallel (P) or Stand-by (S) pump designation
[D] = Manual (M) or Automatic (A) alternation for multiple pumps

GENERAL - This package shall be factory assembled with pump(s), air separator, expansion tank, triple duty valves, hydronic accessories, fabricated steel frame, interconnection piping (welded per ASME Section IX certified welders), UL-listed Industrial Control Panel factory wired for single-point field connection per NEC, (and including Variable Speed Pump Controller).

PUMPS-Pump(s) shall be single, end-suction type with radically split, top center-line discharge, self-venting casing. Pump construction shall be cast iron, bronze fitted and shall be fitted with a long-life, product lubricated, drip tight mechanical seal, with O-ring seat retainer. Impeller shaft to be 416SS fitted with a SS shaft sleeve and be supported by two heavy duty ball bearings. The design shall allow back pull out servicing, enabling the complete rotating assembly to be removed without disturbing casing piping connections. The pump shall be mounted on a rigid, single base plate and by flexible with guard to the motor. Seal shall be rated for continuous duty at 270°F, motor shall be open drip proof, NEMA MG-1 with 1.15 service factor

VARIABLE FREQUENCY DRIVE – Variable Frequency Drive shall be variable torque AC inverter enclosed in NEMA 1 or 12 enclosure. Standard features shall include circuit breaker disconnect, Hand-Off-Auto selector switch, manual potentiometer (speed pot), door-mounted keypad, run relay contacts, fault relay contacts, and top/bottom conduit entry. Drive bypass shall be provided as standard with Drive-Off-Bypass selector switch. Class 20 overloads are included.

SYSTEM CONTROLLER – Controller shall include all controls necessary to operate the system as a stand-alone system. The PLC-based controller shall be of the same manufacturer as the Packaged Pumping System. Controller shall include Remote/Local system start capability. Acceptance of up to 16 remote 4-20 ma signals shall be provided for modulation of pump speed, and other optional control functions. Enclosure shall be NEMA 12 with thru-the-door disconnect. Operator Interface shall be a color touch screen type. Controller shall include independent PID control loop for each remote signal.

AIR REMOVAL EQUIPMENT- System shall include one tangential air separator with internal stainless steel collector tube. Connections to be flanged with a rating of 150 psig. System shall be equipped with ¾" Pressure Relief Valve, ¾" Pressure Regulating Valve, ASME Compression / Expansion Tank (sized by or provide system volume and temperature difference), and tank fitting, sight glass, and tank drain connections to tank.

TRIPLE DUTY VALVE- System shall include, on the discharge of each pump, a combination valve incorporating three functions in one body: tight shut-off, spring closure type silent non-slam check, and flow measured/throttling. Valve body shall be ductile iron with two ¼" NPT connections on each side of the valve seat. The valve disc shall be bronze plug disc type with high impact engineered resin seat to ensure tight shut-off and silent check valve operation. Valve stem shall be SS with flat surfaces provided for adjustment with open end wrench.

SUCTION DIFFUSER- System shall include, on the suction of each pump a suction diffuser with cast iron body, outlet guide vanes and removable SS strainer.

CONTROL PANEL - System shall include one (1) UL - Listed, NEMA 12, Industrial Control Panel with single-point power connection, pre-wired to all electrical components. Panel shall have thru-the-door fused disconnect; magnetic circuit breaker supplementary motor protector with fast-closing contacts, non-reversing 3-pole contactor, and variable setting, bi-metallic overload relay for each motor; 30 mm Foundry-duty switches; 30 mm Corrosion Resistant pilot lights; control transformer; Automatic Alternator (if required). Operation of each pump shall be Hand-Off-Auto with external connection to terminal blocks. When standby pump(s) are used, the standby pump(s) shall manually/ automatically (customer specified) start on primary pump failure. All internal wiring shall be placed in conduit.

MAKE-UP WATER ASSEMBLY - Make-up Water Assembly shall be pre-piped and installed into system suction header; including, Self-contained, Cast Iron Pressure Reducing Valve, set @ 12 psig; Bronze isolation and bypass valves; Cast Iron Y-strainer; Bronze Backflow Preventer; System Pressure Relief Valve, set @ 75 psig; and Liquid Filled Pressure Gauge with Bronze Isolation Valve.

BUTTERFLY VALVES - System Butterfly Isolation Valves shall be Lug-mounted, Cast Iron with 10-position Lever Operator for 6" and below; and Gear Operated above 6" in size. Disc shall be Al-Br or Stainless Steel. Seat material shall be Buna-N or EPDM.

BALL VALVE - Isolation Ball Valves shall be Bronze 2-pc with 316L Stainless Steel Ball and RTFE seats. All Valves shall have Latch-lock lever for Lock-Out procedures.

MANUFACTURER - Shall assume system liability, and performance guarantee and warranty all equipment on system for 12 months after initial start-up.

